

# SAFA STAR Building Cleaning (L.L.C.)

PO BOX # 49486, DUBAI UAE, TEL: 04 2399454 / 055 440 1509

[sales@safastardubai.com](mailto:sales@safastardubai.com) / [admin@safastardubai.com](mailto:admin@safastardubai.com)

Reference Number: SS-WTC-APS-2025-6140

Service Order: 6140

## Water Tank Cleaning & Disinfection Report

M/S AMITY PRIVATE SCHOOL, SHARJAH UAE.



[www.safastardubai.com](http://www.safastardubai.com)  
[admin@safastardubai.com](mailto:admin@safastardubai.com)



CB-037-MS

## Contents

- 1.0 Introduction
- 2.0 Cleaning Methodology
- 3.0 Main Findings
- 4.0 Recommendations
- 5.0 Water Tank Cleaning Pictures (Before & After)
- 6.0 Water Tank Cleaning & Disinfection Certificate
- 7.0 Inspection Report – Pre-Hygiene
- 8.0 After Service Report – Post Hygiene

### 1.0 Introduction

Following completion of an inspection were advice to perform a thorough cleaning & disinfection of the water tanks system to increase its performance and to minimise the risk of potentially harmful bacteria multiplying.

### 2.0 Cleaning Methodology

All the water tanks were drained and cleaned manually using high pressure Wash & cleaning and disinfecting **food grade** chemical HYGIEN X

- Clean all water tanks



### 3.0 Main Findings

- The ground tank was found with heavy staining due to ageing and filled with sand & sludge
- The roof tank was found is physically good condition but dirty with sand settled in the bottom of tank and biofilm on the sides of the tank
- Contaminations cleaned were sand, sludge, biofilm and light staining.

### 4.0 Recommendations

- We highly recommend the cleaning & Disinfection of the water tanks should be conducted every 6 months at the minimum.
- The ground tank needs to be recoated/painted.

**5.0 Water Tank Cleaning Pictures:**

**RCC Tank - 1**

**Before Cleaning**



**After Cleaning**





# SAFA ST R Building Cleaning (L.L.C.)


صفا ستار لتنظيف المباني (ش.ذ.م.م)

PO BOX # 49486, DUBAI UAE, TEL: 04 2399454 / 055 440 1509

[sales@safastardubai.com](mailto:sales@safastardubai.com) / [admin@safastardubai.com](mailto:admin@safastardubai.com)

## GRP Tank - 1

### Before Cleaning



### After Cleaning



# SAFA ST★R صفا ستار لتنظيف المباني (ش.ذ.م.م) Building Cleaning (L.L.C.)

PO BOX # 49486, DUBAI UAE, TEL: 04 2399454 / 055 440 1509

[sales@safastardubai.com](mailto:sales@safastardubai.com) / [admin@safastardubai.com](mailto:admin@safastardubai.com)

## GRP Tank - 2

### Before Cleaning



### After Cleaning



# SAFA ST R صفا ستار لتنظيف المباني (ش.ذ.م.م) Building Cleaning (L.L.C.)

PO BOX # 49486, DUBAI UAE, TEL: 04 2399454 / 055 440 1509

[sales@safastardubai.com](mailto:sales@safastardubai.com) / [admin@safastardubai.com](mailto:admin@safastardubai.com)

## GRP Tank - 3

### Before Cleaning



### After Cleaning





PO BOX # 49486, DUBAI UAE, TEL: 04 22399454 / 055 440 1509  
sales@safastardubai.com/admin@safastardubai.com

**WATER TANK SYSTEM**  
**CLEANING & DISINFECTION**  
**CERTIFICATE**

This certificate is issued in favor of ***M/S Amity Private School*** on the ***05<sup>th</sup> APRIL . 2025***, towards the cleaning and disinfection of the Water Tank System.

The procedures employed in this cleaning and disinfection complies with Dubai Municipality guidelines for cleaning and disinfection of water storage tanks as well as Safa Star Building Cleaning Services method statement.

It is recommended that the entire water Tank system should be cleaned and disinfected minimum every six (06) months depending upon its condition.

The cleaning was conducted on ***03<sup>RD</sup> N 04<sup>TH</sup> APRIL. 2025.***

The next cleaning is due/Scheduled in ***OCOTBER 2025.***

On Behalf of  
**Safa Star Building Cleaning LLC**  
**05<sup>th</sup> APRIL. 2025**



## WTC - POST-HYGIENE/AFTER SERVICE REPORT - SERVICE ORDER - 6140

CLIENT INFO	CLIENT NAME		M/S AMITY PRIVATE SCHOOL						
	ADDRESS/LOCATION		SHARJAH UAE						
	BUILDING TYPE		RESI	COMM	SCHOOL	CAMP	VILLA	HOTEL	OTHERS
	TANK LOCATION		GROUND LEVEL		ON ROOF	STEEL MOUNTED		BASEMENT	
	TYPE		RCC	GRP	GRP	S/STEEL	GALV.	POLYURETHANE	
			1 NO	1 NO	2 NOS				
	CAPACITY (USG)		240,000	5,000	20,000				
VISUAL INSPECTION									
EXTERNAL INSPECTION	1	ANY GARBAGE/WASTE COLLECTION		NIL	5	EXTERNAL DAMAGE/IF ANY		NIL	
	2	ANY DRAINAGE WATER COLLECTION		NIL	6	MANHOLE/ENTRY LID (FITTED)		YES	
	3	WATER INLET PIPE.VALVE LEAKAGE		NIL	7	VENT SCREEN		NA	
	4	WATER INLET/OUTLET VALVE WORKING?		YES	8	EXTERNAL LADDER		NA	
	ANY OTHER OBSERVATIONS		1 NO. RCC TANK AND 3 NO. GRP TANKS CLEANED & DISINFECTED.						
	INTERNAL WALLS HAND SCRUBBED, HIGH PRESSURE WASHED, DISINFECTED N FLUSHED WITH CLEAN WATER.								
INTERNAL INSPECTION			OTHER REMARKS/ACTION REQUIRED						
	FLOAT VALVE OPERATIONAL		YES						
	INTERNAL LADDER		OK						
	CONDITION OF INTERNAL WALLS								
	CRACKS			RUSTY/STAINING		BIOFILM			
	N/A			NIL		CLEANED			
	ANY SEDIMENTS/DEBRIS INSIDE THE TANK								
	NIL - ALL CLEANED								
ANY OTHER OBSERVATIONS									
TESTS	CHEMICALS USED				SAMPLES RESULTS				
	1	HYGINE X	18.0L		PH	6.8/7.0			
	2				TDS	300 - 340			
	3				LAB REPORT	SATISFACTORY			
	4								
REPORT SIGNATURE	ASSESSMENT REPORT		SATISFACTORY						
	NEXT SERVICE/CLEANING SCHEDULED		OCTOBER 2025						
	INSPECTOR'S NAME					CLIENT'S REPRESENTATIVE			
	SIGNATURE					SIGNATURE			
	DATED		05/04/20245						
NOTE: TICK - YES/NO - AS APPROPRIATE (REV. DEC. 2012)									

# SAFA ST★R

صفا ستار لتنظيف المباني (ش.ذ.م.م)  
Building Cleaning (L.L.C.)

No. 6140

P.O. Box : 49486, Dubai - United Arab Emirates

Tel : 04 2399454 / 05 54401509

E-mail : admin@safastardubai.com, sales@safastardubai.com, www.safastardubai.com

JOB #	SERVICE ORDER				DATE	03/04/2025			
CUSTOMER DETAILS				CONTACT PERSON		Kutebuddin Jamsal			
LOCATION				OFFICE TEL #		FAX #			
Amity private school Sharjah, Uae,				MOB #		0547909171		E-MAIL	
SERVICE REQUESTED / APPROVED									
A	DEEP CLEANING WORKS	VILLA		APARTMENT		OFFICE		OTHERS	
B	EXTERNAL GLASS CLEANING	VILLA		TOWER		HOTEL		COMMERCIAL	
C	WATER TANK CLEANING / DISINFECTION	VILLA		LABOUR CAMP		HOTEL		OTHERS	
D	ROPE ACCESS SERVICES					SPECIAL INSTRUCTIONS/NOTES			
F	CARPET CLEANING / SOFA SHAMPOOING					We have completed water tank cleaning and disinfection, Total tank - 04 Nos G.F - R.C.C tank - 01 Nos G.F - G.R.P tank - 01 Nos R.T - G.R.P tank - 02 Nos			
G	KITCHEN DUCT CLEANING								
H	GREASE TRAP CLEANING								
I	A/C DUCT CLEANING								
J	HIGH PRESSURE WASHING & CLEANING								
K	OTHERS					STAFF ON DUTY/TIMINGS			
Next cleaning service on October - 2025						START TIME			
						CLOSING TIME			
						SITE IN-CHARGE	Kabir		
						TECHNICAL/HELPERS	Kamran		
							Nikash		
							Matfuz		
							Mustafa		
							Naim		
							Riaz		
WORK CHECKED/VERIFIED BY		CLIENT'S APPROVAL							
0554401509 		I HEREBY CERTIFY THAT THE WORK HAS BEEN CARRIED OUT FULLY TO MY SATISFACTION 							
Name/Signature		Name/Signature				END DATE 04/04/2025			

★ DEEP CLEANING - VILLAS/APARTMENTS ★ CONTRACT CLEANING - OFFICES/SHOWROOMS

★ WATER TANK CLEANING ★ PIPELINE FLUSHING SERVICES ★ KITCHEN DUCT CLEANING ★ AC DUCT CLEANING

★ CARPET / SOFA SHAMPOOING ★ DISINFECTION / SANITIZATION SERVICES ★ GENERAL MAINTENANCE & PEST CONTROL SERVICES

Sr. No. 00001

# Operator's Permit

As

Water Tank Cleaning Company

This is to certify that

## Safa Star Building Cleaning LLC .

Commercial License No. 545950

Complies with DM- Food Safety Department requirements for Water Tank Cleaning in the

Emirate of Dubai

Registration and Permits and Section

Issue Date: 14/02/2025

Expiry Date: 13/02/2026

DM-FSD-FO68, Rev:03, Issue Date:16/08/09

Kindly be informed that the attached permit (Water Tank Cleaning and Disinfection Permit) is approved with regards of food safety requirements.

Note: For any inquiry kindly contact Registration and Permits Section via email address

[FoodPermits@dm.gov.ae](mailto:FoodPermits@dm.gov.ae)